



INDICATOR REFERENCE

POWER ON

POWER OFF

DEHUMID.

DEFROST





ISSUE	DATE	AMENDMENTS
1	01/09/25	ORIGINAL
2	21/11/25	JUMPERS / MOTOR / PUMP N.O. CHANGED - WDA
3	21/08/26	CONTROLS EARTH STUD ORDER CHANGED - WDA

NOTE:
ENSURE CONTACTORS ARE USED CORRECTLY

C1 - FAN
3030301 - 3RT2016-1AP01
9A CONTACTOR

C2 - COMPRESSOR
3030321 - 3RT2018-1AP01
16A CONTACTOR



TITLE	
CD425 220V / 3PH / 60Hz - WITH PUMP	
MATERIAL	DRAWN: W DAGLISH
N/A	CAD SCALE: 1/1
FINISH	DRG.NO. 5010605
N/A	SHEET 1 OF 1